



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 15.09.2020

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	113	111	02	H. No. B-83, Gali No. 13, Wazirabad Village H. No. A-74, Gali No. 2, Mukundpur	Hazy	Nil
2	Haiderpur	95	95	Nil	--	--	--
3	Bhagirathi / TYR	63	58	05	H. No. 110/14A, 10/11A, 9/127 Subhash Gali Vishwas Nagar H. No. B-87, B109, Radhey Shyam Park	Turbid	Nil
4	Greater Kailash	88	88	Nil	--	--	--
5	Okhla	59	59	Nil	--	--	--
6	Nangloi	213	213	Nil	--	--	--
7	Dwarka	60	60	Nil	--	--	--
8.	Bawana	29	29	Nil	--	--	--
	Total	720	713	07			

% of Unsatisfactory Samples – 0.9

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)

[Type text]